

Cleaning:

- > Clean this light fitting only with a soft dry cloth—Do not use any chemical or abrasive cleaners.

Lamp replacement:

- > Switch off the electricity at the mains.
- > Remove the diffuser.
- > Twist and withdraw the tube.
- > Insert new tube.
- > Restore the power and perform operation check.
- > Replace diffuser.

Replacement lamp type:

Wattage: 8 W
Type: T5 fluorescent tube

Replacement battery type:

2.4V Ni-Cad
7030-0621

Battery replacement:

If after routine operation check, the lamp does not remain lit for the three hour period, a new battery pack may be required.

- 1) Switch off the electricity at the mains.
- 2) Allow batteries to fully discharge then reconnect to supply and allow to charge for 24 hours.
- 3) Test again for 3 hours, if light does not remain lit change the battery pack as follows:
- 4) Remove the diffuser.
- 5) Remove the two screws indicated on the gear tray and open the fitting.
- 6) Unplug the battery lead from the circuit board.
- 7) Remove the two screws in the top of the gear tray beneath the lamp that secure the battery pack in place and lift the battery pack out of the fitting.
- 8) Write current date on the new battery pack.
- 9) Fit new battery pack securing in place using the screws removed from the old pack.
- 10) Plug battery pack into circuit board.
- 11) Close and secure gear tray
- 12) Replace diffuser.
- 13) Restore power and allow to charge for 24 hours.
- 14) Perform full operation check and update test record.

Eventually, you may want to replace this light fitting:

When your light fitting and or battery pack come to the end of their life or you choose to update or upgrade the fitting by replacing it, please do not dispose of it with your normal household waste, please recycle where facilities exist. When you need to dispose of this fitting, check with your retailer or local authority for suitable options. New regulations will encourage the recycling of Waste from Electrical and Electronic Equipment (European "WEEE Directive" effective August 2005).



If you experience problems:

If your light is defective or develops a fault, please return it to the place where you bought it. You can call our Helpline for advice. The Helpline will gladly give advice on any aspect of any Eterna Lighting product but may not be able to give specific instructions regarding individual installations.

If in doubt, consult a qualified electrician.

Help line:

Tel: 01933 673 144 Fax: 01933 678 083 Email: sales@eterna-lighting.co.uk
For answers to frequently asked questions (FAQs) and other information visit our web-site
www.eterna-lighting.co.uk



IMPORTANT!

Safety and Installation instructions

Non-maintained emergency bulkhead light 8W

Model(s)
YD630NM

Specification:

Power	8W
Continuous illumination	>3 hours
Battery	2.4V 4.5Ah
Recharge time	~20 hours
Over-discharge protection	Yes

**PLEASE READ THESE INSTRUCTIONS BEFORE
INSTALLING YOUR NEW FITTING**

PLEASE RETAIN FOR FUTURE REFERENCE

Read this first:

- > **This light fitting must be installed in accordance with the Building Regulations.** These may be obtained from HMSO or viewed and downloaded from www.odpm.gov.uk following the link for Building Regulations.
- > Switch off the mains before commencing installation and remove the appropriate circuit fuse.
- > Do not connect to a circuit which also has inductive loads connected as spikes generated switching inductive loads may damage electronic components within your light fitting.
- > Suitable for indoor or outdoor use.
- > This product is suitable for installation on flammable surfaces (indicated by the "F" in a triangle)
- > Before making fixing hole(s), check that there are no obstructions hidden beneath the mounting surface such as pipes or cables.
- > The chosen location of your new fitting should allow for the product to be securely mounted (e.g. to a ceiling joist) and safely connected to the mains supply (lighting circuit).
- > Ensure that the fitting will be accessible after installation for maintenance.
- > If the location of your new fitting requires the provision of a new electrical supply, the supply must conform with the requirements of the Building Regulations.
- > Make connections to the electrical supply in accordance with the following code:
 Live - Brown or Red
 Neutral - Blue or Black
 Earth - Green and Yellow
- > This product must be connected to Earth.
- > You are advised at every stage of your installation to double-check any electrical connections you have made. After you have completed your installation there are electrical tests that should be carried out: these tests are specified in the Wiring Regulations (BS7671) referred to in the Building Regulations. If in doubt, consult a qualified electrician.

Installation:

- 1) Undo the screws at each end of the diffuser and lift off.
- 2) Remove the screws on the gear tray marked
- 3) "Remove this screw to open" and remove the two screws that are recessed with a plastic surround. Note the orientation of the plastic hinges. Lift off the gear tray. Take care not to lose the small plastic hinges that will be removed with two of the screws.
- 4) Make the cable entry and fixing holes as required. Inside the back of the fitting, there are markings to assist you.
- 5) Using the back of the fitting as a template, mark the position of the fixing holes on your mounting surface.
- 6) Make fixing holes and fit plugs as appropriate.
- 7) Secure the back of the fitting to the mounting surface using suitable fixings (not supplied).
- 8) Apply a silicon sealant to the fixings if moisture- or weather-proofing is required.
- 9) Fitting a cable gland will also be necessary if moisture- or weather-proofing is required.
- 10) Thread the supply cable through the entry point and into the fitting.
- 11) Holding the gear tray in position in the fitting, replace the two screws with the plastic hinges into the screw holes with the plastic surround and tighten. Ensure that the hinge is replaced the correct way round.
- 12) Lift the gear tray out on it's hinge and make connection to the mains supply. Normally, the supply will be taken from the lighting circuit and the permanent live connected to the live terminal in the fitting. Make connections according to the wiring colour code above.
- 13) Write the current date of the battery pack.
- 14) Connect the battery pack to the circuit board.
- 15) Close the gear tray and secure with the two remaining screws. For future maintenance, only the screws indicated on the gear tray need to be removed.
- 16) Replace the diffuser.
- 17) Restore the power supply. The LED should light to indicate correct charging.

Operation checks:

This light fitting must be checked regularly in compliance with local regulation and codes of practice. For your own safety, testing should occur during the day.

After installation, you should allow 24 hours for the battery pack to charge fully before testing. Isolate the power supply and check that the light remains illuminated for at least three hours. Restore the power supply.

Each day:

Check that the charging indicator LEDs are lit.

Each month:

Isolate the power supply and check the light remains illuminated. Endorse the test record form below.

Every six months:

Isolate the power supply and check that the light is still illuminated after 1 hour. Endorse the test record form below.

Once each year:

Isolate the power supply and check that the light is still illuminated after 3 hours. Endorse the test record form below.

Please keep this instruction booklet and test record in a safe place. A fire officer or other authorised person may want to see your record of inspection and testing.

Installation, maintenance and operation check record

Location:

Installation date:

Installation test duration:

Installed by:

Month	Test	20__		20__		20__		20__		20__	
		Sign	Date	Sign	Date	Sign	Date	Sign	Date	Sign	Date
1	Short										
2	“										
3	“										
4	“										
5	“										
6	1 hour endurance										
7	Short										
8	“										
9	“										
10	“										
11	“										
12	3 hour endurance										

YD630NM Non-maintained emergency bulkhead light 050414PA

Safety markings:

